



To

The Principal
Amatir Kanya Gurukul
Bachgaon Gamri Kurukshetra

No. 2017

Dated: 23.6.2023

Subject: Issue Certificate for School Building Safety.

Reference: Your office letter No. ^{54/AKG/}2022-24 dated 10.06.2023

In this connection, it is submitted that the building of Amatir Kanya Gurukul Bachgaon Gamri Kurukshetra has been inspected by the concerned Sub Divisional Engineer, Provincial Sub Division No.3, PWD B&R, Pipli along with concerned Junior Engineer and found to be safe as per visual inspection of the structure of the building. The school Building Safety Certificate is hereby given upto the period 2023-24 with the following conditions as per recommendations received from the SDE, PSD-3, Pipli:-

1. Building of this school should be repaired every year.
2. Water should not be allowed to stagnate around and on the roof of the Building.
3. If Building is found cracked from anywhere, the same should be got vacated immediately and same should be got repaired immediately.
4. Institution will be responsible for safety of building from every angle and Fire-Fighting equipment should be in functional condition.
5. If the building of the school is to be extended, the same should be first approved from Structural Engineer.
6. Adequate Fire safety may be adopted in the school campus.
7. Institute shall also ensure safety precautions from false ceiling and vitrified tiles used in dado.
8. NOC may be considered as cancelled by this office if the college violates any of the above points.

Executive Engineer,
Provincial Division No.1,
PWD B&R, Kurukshetra

DA/ Nil
Endst No.

Dated

Copy forwarded to the SDE, PSD-3, PWD B&R, Pipli letter No. 338 dated

20.6.2023.

DA/ Nil



Executive Engineer,
Provincial Division No.1,
PWD B&R, Kurukshetra